

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1341:101 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Safetech International Inc, 13402 W. 92nd St., Lenexa, KS 66215
Contact: Gaylen Davenport (913) 894-4855

DESIGN: Models 1005, 1005+, 1010, 1010+ fire alarm control units. Power-limited. Automatic, manual, local, remote station, central station, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

<u>Model</u>	<u>Part No.</u>	<u>Description</u>
CPU1	2904	CPU Board
CPU1+	2905	CPU Board+
EMB1	2908	5-Zone Expansion Module
ZRM5	2918	5-Zone Relay Module
SCP1	2909	RS232 Communication Port
RRM	2925	Remote Relay Module
AUX	2300	Auxiliary Relay
*RAN, RAN-EX, RLD, RLD-EX	SD-97-01	Remote Annunciators
*FZA,	SD-97-02	5-Zone Class A Initiating Module
*TZB	SD-97-02	10-Zone Class B Initiating Module
*SDE		Enclosure Backbox

RATING: Primary: 120 VAC, 1.2 A
Secondary: 24 VDC battery

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

*Revised 01-22-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager